



REPORT

issued by notified body No. 0402

0402 – CPD – 22 12 34

Date 2008-11-20 Reference 0402-CPD-221234 Page 1 (3)

Handled by, department
Susanne Hansson
Certification+46 10 516 51 52,
susanne.hansson@sp.se

Hansadoor LCC
Tule street 17
76505 Saue
Estonia

Summary Initial Type-Testing Report for EC Declaration of Conformity for Garage Door

SP Technical Research Institute of Sweden has as Notified Body no. 0402, performed Initial Type-Testing of the products mentioned below according to the requirements in the harmonized standard **EN 13241-1:2003**. This report may be used as support for an EC Declaration of Conformity in accordance with the Construction Products Directive CPD, 89/106/EEC.

Issued for Manufacturer/Factory

Hansadoor LCC, Tule street 17, 76505 Saue, Estonia

Product name and description

Garage door type	HD - RES
Weight of door	Max. weight: 160 kg
Day-light, maximum	width 5000; height 3000 mm
Day-light, tested	width 2500; height 2610 mm
Manufacturer (type of panels)	Ryterna, ThyssenKrupp-Hoesch
Hardware FlexiForce	RES-X (test report SP P403076, 2005-02-07) RES 70 (test report SP P403076, 2005-02-07) RES 200 (test report SP P403076, 2005-02-07) RES 350 (test report SP P704194, 2007-09-18)
Balancing system	Flexi-Force Torsion spring
Spring break device	See chapter 1.5
Machinery / Operator	See chapter 3
Bottom seal	See chapter 3

SP Technical Research Institute of Sweden

Postal address Phone / Fax Reg. number E-mail / Internet
SP +46 10-516 50 00 556464-6874 info@sp.se
Box 857 +46 33-13 55 02 www.sp.se
SE-501 15 Borås
SWEDEN

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval by SP.

1 Test of fully assembled Door

1.1 Wind Load

Test report SP No. P403076, dated Feb 7, 2005

Door (panel) type	Wind load class	Maximum pressure [Pa]
Ryterna	5	1300
ThyssenKrupp Hoesch (Sectiotec®Plus)	5	1300

1.2 Determination of air permeability

Test report SP No. P403076, dated Feb 7, 2005

Door (panel) type	Air permeability class
Ryterna	2
ThyssenKrupp Hoesch (Sectiotec®Plus)	3

1.3 Resistance to water penetration

Test report SP No. P403076, dated Feb 7, 2005

Door (panel) type	Water penetration class	Maximum pressure [Pa]
Ryterna	3	90
ThyssenKrupp Hoesch (Sectiotec®Plus)	3	110

1.4 Thermal resistance

Door panel type 2500 x 2610 mm Test report SP No. P403076, 2005-02-07	Thermal transmittance, U_{door} [W/(m ² K)]			
	p	pw4	pd	g
Ryterna	1.7	1.8	-	-
ThyssenKrupp Hoesch (Sectiotec®Plus)	1.6	1.8	-	-
ThyssenKrupp Hoesch (pass door 0.85x2.40 m)	-	-	2.4	-

p = door with covered panels only

pw4 = covered panels with four windows

pd = covered panels with windows and a pass door

g = fully glazed door

1.5 Safe opening

Component (FF = Flexi-Force)	Door weight	Test report SP No, date
Spring break device FF type type 651, 667	225 kg	P403076, 2005-02-07
Spring break device FF type type 656	170 kg	P705408J, 2007-12-19

1.6 Dangerous substances

Requirement	Result	Test Report, dated
Dangerous substances	Pass	SP No. P403076, 2005-02-07

1.7 Durability of water tightness, thermal resistance and air permeability

Requirement	Result	Test Report, dated
Durability of water tightness, thermal resistance and air permeability	Pass	TNO 2005-BCS-R0014, Jan 11, 2005 (TNO Built Environment and Geosciences, The Netherlands)

2. Single panel test, resistance to wind load

Test report No. P403076, dated Feb 7, 2005

Door panel type	Width [mm]	Height [mm]	Wind load Class [Pa]		Maximum pressure [Pa]
Ryterna, E 48119 M-DB FXF-CND	2550	490	5	3 522	4 842
Ryterna	5000	490	3	-	1 251
Ryterna, 3 windows FF type 2240E 48119 M-DB	2550	490	5	1 270	1 756
Ryterna, five windows 420*280	5000	490	2	-	693
ThyssenKrupp Hoesch (Sectiotec®Plus)	2540	490	5	3 724	5 120
ThyssenKrupp Hoesch (Sectiotec®Plus)	5000	490	3	-	1 282
ThyssenKrupp Hoesch, three windows	2540	610	5	1 616	2 222
ThyssenKrupp Hoesch, five windows 420*280	5000	490	1	-	463

3. Operating forces

Following operators were tested together with the test door and performed in accordance with the requirements. Bottom seal FF = Flexi-Force. The weight of the door was 110 to 160 kg.

Machinery	Bottom seal	Maximum weight [kg]	Test report SP No., dated
Chamberlain Liftmaster 60	FF standard	110	P403076, 2005-02-07
Chamberlain Liftmaster 800	FF standard	110	P403076, 2005-02-07
Chamberlain Liftmaster 1000	FF standard	160	P403076, 2005-02-07
Chamberlain Liftmaster 5580	FF standard	160	P403076, 2005-02-07
BFT EOS 60 chain/(belt) Software 3.3	FF 1039	160	P502949A, 2005-06-20

**SP Technical Research Institute of Sweden
Certification**


Lennart Månsson
Certification Manager


Klas Johansson
Technical Officer